

~~CONFIDENTIAL~~

Chief, FE/Support

5 September 1961

Acting Chief, Real Estate and Construction Division

25X1A6a

[REDACTED] Swimming Pool Facility

25X1A

25X1A

REF : [REDACTED] 5392 dated 14 July 1961

1. The request for a swimming pool for [REDACTED] forwarded by the reference has been reviewed by this office.

25X1A6a

2. Design, equipment and operation of this facility should be in substantial accordance with practices recommended by the American Public Health Association for Swimming Pools and Public Bathing places. If constructed of reinforced concrete, special attention should be given to the design of the mix to assure water tight integrity. It is suggested that the station consider "gunmiting" as an alternative cheaper method of construction.

25X1A

3. The present uncertain status of [REDACTED] would give rise to some question as to whether or not this project should be undertaken. If the FE Division decides to proceed with the construction, Project Review Committee action will be required inasmuch as the cost estimate is in excess of \$25,000.

25X1A6a

25X1A9a

Distribution:

Orig. & 1 - Addressee

① - OL/RECD Project

1 - OL/RECD Chrono

25X1A9a

OL/RECD: [REDACTED] 3023
(5 September 1961)

~~CONFIDENTIAL~~